



Acoustic Consultants Member Australian Acoustical Society

REPORT 180178R1

Revision 1

Noise Impact Assessment Proposed Boarding House 61 Fennell Street, North Parramatta NSW

PREPARED FOR: WARINGA PTY LTD, GLEXIBAN NOMINEES PTY LTD, F CAGNONI, E M A CAGNONI, MJ CAGNONI 61 Fennell Street, North Parramatta NSW 2151

24 May 2019

PO Box 522 Wahroonga NSW 2076 P 02 9943 5057 F 02 9475 1019 mail@rodneystevensacoustics.com.au

Noise Impact Assessment

Proposed Boarding House

61 Fennell Street, North Parramatta NSW

PREPARED BY:

Rodney Stevens Acoustics Pty Ltd Telephone: 61 2 9943 5057 Facsimile 61 2 9475 1019 Email: info@rodneystevensacoustics.com.au Web: www.rodneystevensacoustics.com.au

DISCLAIMER

Reports produced by Rodney Stevens Acoustics Pty Ltd are prepared for particular Clientele objectives and based on a specific scope, conditions and limitations, as agreed between Rodney Stevens Acoustics and the Client. Information and/or report(s) prepared by Rodney Stevens Acoustics may not be suitable for uses other than the original intended objective. No parties other than the Client should use any information and/or report(s) without first conferring with Rodney Stevens Acoustics.

The information and/or report(s) prepared by Rodney Stevens Acoustics is not be re-produced, presented or reviewed, except in full. Before passing on to a third party any information and/or report(s) prepared by Rodney Stevens Acoustics, the Client is to fully inform the third party of the objective and scope and any limitations and conditions, including any other relevant information which applies to the material prepared by Rodney Stevens Acoustics. It is the responsibility of any third party to confirm whether information and/or report(s) prepared for others by Rodney Stevens Acoustics are suitable for their specific objectives.

DOCUMENT CONTROL

Reference	Status	Date	Prepared	Checked	Authorised
180178R1	Revision 0	17 September 2018	Dani Awad	Desmond Raymond	Rodney Stevens
180178R1	Revision 1	24 September 2019	Dani Awad	Desmond Raymond	Rodney Stevens

TABLE OF CONTENTS

INTR	ODUC	CTION	5
1	PRO	POSED DEVELOPMENT	5
	1.1	Site Location	5
	1.2	Proposed Development	6
2	EXIS	STING ACOUSTIC ENVIRONMENT	6
	2.1	Unattended Noise Monitoring	6
	2.2	Ambient Noise Level Results	6
3	NOIS	SE CRITERIA	7
	3.1	Road Noise and Vibration Criteria 3.1.1 Parramatta City Council Requirements 3.1.2 State Environmental Planning Policy (Infrastructure) 2007	7 7 7
	3.2	Operational Noise Project Trigger Noise Levels3.2.1Intrusiveness Noise Levels3.2.2Amenity Noise Levels3.2.3Area Classification3.2.4Project Specific Trigger Noise Levels	8 8 9 9
4	NOIS	SE IMPACT ASSESSMENT	10
	4.1	Road Traffic Noise 4.1.1 Road Traffic Noise Intrusion Assessment	10 10
5	REC	OMMENDED NOISE CONTROL TREATMENT	10
	5.1	Glazing 5.1.1 Rw Requirements for Glazing	10 11
	5.2	Mechanical Ventilation	11
6	OPE	RATIONAL NOISE ASSESSMENT	12
	6.1	Mechanical Plant Noise Assessment	12
	6.2	Typical Vocal Levels	12
	6.3	Tenant Sound Power Levels	12
	6.4	Noise Emissions Calculation	13
	6.5	Predicted Noise Levels	13
	6.6	Outdoor Communal Area Mitigation Recommendations	14
7	CON	ICLUSION	15
Table Table Table Table	2-1 3-1 3-2 4-1	Measured Ambient Noise Levels DP&I Interim Guideline Noise Criteria Project Specific Trigger Noise Levels Measured Traffic Noise Levels	6 8 9 10
i able	96-1	Speech Spectrums - Handbook of Acoustical Measurements and Noise Control.	12

((((((()©

		(((((((©))
Table 6-2	Sound Power Levels of People talking with Raised Voice - $Lw - dB(A)$	12
Table 6-3	Predicted Noise Levels at sensitive receivers.	14
Figure 1-1	Site Location	5
Figure 6-1	Sensitive Receiver Location	13



INTRODUCTION

Rodney Stevens Acoustics Pty Ltd (here forth referred to as RSA), has been engaged by WARINGA PTY LTD, GLEXIBAN NOMINEES PTY LTD, F CAGNONI, E M A CAGNONI and MJ CAGNONI to conduct a noise impact assessment for Development Application (DA) lodgment of the proposed boarding house at 61 Fennel Street, North Parramatta.

This report will address traffic noise impact from Fennell Street and Brickfield Street on the amenity of the proposed boarding house in addition to any mechanical plant, carpark and outdoor communal area noise caused by the site on nearby sensitive receivers.

This assessment is to form part of the supporting documentation for the DA submission to Parramatta City Council.

Specific acoustic terminology is present throughout this report. An explanation of these acoustic terms is provided in Appendix A

1 PROPOSED DEVELOPMENT

1.1 Site Location

The proposed residential development site is located at 61 Fennel Street, North Parramatta. It is bounded by residential premises to the north, east and south and west. The location of the proposed site and surrounding area is presented in Figure 1-1.



Figure 1-1 Site Location

Aerial image courtesy of Near Map © 2018

1.2 Proposed Development

The proposal consists of the construction of a three-story boarding house comprising of 19 boarding rooms split between the ground, first and second floor. The site will have an outdoor communal area and 2 basement levels. The architectural plans of the proposed residential development are presented in Appendix C.

2 EXISTING ACOUSTIC ENVIRONMENT

2.1 Unattended Noise Monitoring

In order to characterize the existing acoustical environment of the area, RSA carried out unattended noise monitoring between Thursday 24 May and Thursday 31 May 2018 at the logging location shown in Figure 1-1. The noise monitoring at this location is representative of the acoustic environment at the project site.

RSA selects logger location with consideration to; other noise sources, which may influence readings, equipment security issues and gaining permission for access from other landowners.

Instrumentation for the survey comprised of two RION NL-42 environmental noise loggers (serial numbers 572559 and 572542) fitted with a microphone windshield. Calibration of the loggers was checked prior to and following measurements. Drift in calibration did not exceed ±0.5 dB (A). All equipment carried appropriate and current NATA (or manufacturer) calibration certificates.

2.2 Ambient Noise Level Results

In order to assess the acoustical implications of the proposed development on the levels of noise received at the neighboring residential and commercial premises, the measured data was processed according to the NSW Environment Protection Authority (EPA) and Noise Policy for Industry (NPfI) assessment time periods. Table 2-1 details the RBL (background) and L_{Aeq} noise levels recorded during the daytime, evening and nighttime periods.

		Noise Leve	I – dB(A) re 20 μΡa	i i	
D	ay	Eve	ning	I	Night
RBL ¹	L _{Aeq} ²	RBL ¹	L _{Aeq} ²	RBL ¹	L _{Aeq} ²
37	51	37	50	32	45

Table 2-1 Measured Ambient Noise Levels

Note 1: The RBL noise level is representative of the average minimum background sound level (in the absence of the source under consideration), or simply the background level

Note 2: The L_{Aeq} is essentially the average sound level. It is defined as the steady sound level that contains the same amount of acoustical energy as a given time-varying sound.

3 NOISE CRITERIA

3.1 Road Noise and Vibration Criteria

The determination of an acceptable level of road noise that will impact internal residential spaces requires consideration of the activities carried out within the space and the degree to which noise will interfere with those activities.

As sleep is the activity most affected by traffic noise, bedrooms are considered to be the most sensitive internal living areas. Higher levels of noise are acceptable in living areas without interfering with activities such as reading, listening to the television etc. Noise levels in utility spaces such as kitchens, bathrooms, laundries etc. can be higher.

3.1.1 Parramatta City Council Requirements

Parramatta City Council has specific requirements for traffic noise intrusion into residential spaces. These requirements are detailed in the Parramatta City Council's DCP and pertain to the SEPP (Infrastructure) 2007 they are as follows:

State Environmental Planning Policy (Infrastructure) 2007

Appropriate measures must be taken to ensure that the following LAeq levels are not exceeded:

In any bedroom in the building – 35 dB(A) at any time between 10 pm and 7 am

Anywhere else in the building (other than a garage, kitchen, bathroom or hallway) – 40 dB(A) at any time

Environmental Health

An acoustic report is to be prepared by an appropriately qualified acoustic consultant having the technical eligibility criteria required for membership of the Association of Australian Acoustical Consultants (AAAC) and/or grade membership of the Australian Acoustical Society (MAAS). The report shall consider noise intrusion from the road and measures to ensure compliance with SEPP (Infrastructure) 2007. The report should also consider noise emissions from the development including but not limited to proposed mechanical plant (air conditioners, lift shift, automatic roller doors, and ventilation plant for the underground car park) and construction/vibration impacts. The report should be prepared in accordance with the NSW Environment Protection Authority Industrial Noise Policy, EPA's Interim Construction Noise Guidelines & NSW DP&I's Development near Rail Corridors and Busy Roads – Interim Guideline

3.1.2 State Environmental Planning Policy (Infrastructure) 2007

Road and Rail Noise Criteria

The NSW Government's State Environmental Planning Policy (Infrastructure) 2007 (SEPP (Infrastructure) 2007) was introduced to facilitate the delivery of infrastructure across the State by improving regulatory certainty and efficiency. In accordance with the SEPP, Table 3.1 of the NSW Department of Planning and Infrastructure's "*Development near Rail Corridors and Busy Roads - Interim Guideline*" (the DP&I Guideline) of December 2008 provides noise criteria for residential and non-residential buildings. These criteria are summarized in Table 3-1.

Table 3-1 DP&I Interim Guideline Noise Criteria

Type of occupancy	Noise Level dB(A)	Applicable time period
Sleeping areas (bedroom)	35	Night 10 pm to 7 am
Other habitable rooms (excl. garages, kitchens, bathrooms & hallways)	40	At any time

Note 1: Airborne noise is calculated as $L_{Aeq (15hour)}$ daytime and $L_{Aeq (9hour)}$ night-time

The following guidance is provided in the DP&I Guideline:

"These criteria apply to all forms of residential buildings as well as aged care and nursing home facilities. For some residential buildings, the applicants may wish to apply more stringent design goals in response to market demand for a higher quality living environment.

The night-time "sleeping areas" criterion is 5 dB (A) more stringent than the "living areas" criteria to promote passive acoustic design principles. For example, designing the building such that sleeping areas are less exposed to road or rail noise than living areas may result in less onerous requirements for glazing, wall construction and acoustic seals. If internal noise levels with windows or doors open exceed the criteria by more than 10 dB(A), the design of the ventilation for these rooms should be such that occupants can leave windows closed, if they so desire, and also to meet the ventilation requirements of the Building Code of Australia."

The noise criteria presented in Section 3.1.2 and in Table 3-1 apply to a 'windows closed condition'. Standard window glazing of a building will typically attenuate noise ingress by 20 dB(A) with windows closed and 10 dB(A) with windows open (allowing for natural ventilation). Accordingly, the external noise threshold above which a dwelling will require mechanical ventilation is an $L_{Aeq(9hour)}$ of 55 dB(A) for bedrooms and $L_{Aeq(15hour)}$ of 60 dB(A) for other areas.

Where windows must be kept closed, the adopted ventilation systems must meet the requirements of the Building Code of Australia and Australian Standard 1668 – The use of ventilation and air conditioning in buildings.

3.2 Operational Noise Project Trigger Noise Levels

Responsibility for the control of noise emissions in New South Wales is vested in Local Government and the EPA. The EPA oversees the Noise Policy for Industry (NPfI) October 2017 which provides a framework and process for deriving project trigger noise level. The NPfI project noise levels for industrial noise sources have two (2) components:

- Controlling the intrusive noise impacts for residents and other sensitive receivers in the short term; and
- Maintaining noise level amenity for particular land uses for residents and sensitive receivers in other land uses.
- 3.2.1 Intrusiveness Noise Levels

For assessing intrusiveness, the background noise generally needs to be measured. The intrusiveness noise level essentially means that the equivalent continuous noise level (LAeq) of the source should not be more than 5 dB(A) above the measured Rated Background Level (RBL), over any 15-minute period.

3.2.2 Amenity Noise Levels

The amenity noise level is based on land use and associated activities (and their sensitivity to noise emission). The cumulative effect of noise from industrial sources needs to be considered in assessing the impact. The

noise levels relate only to other industrial-type noise sources and do not include road, rail or community noise. The existing noise level from industry is measured.

If it approaches the project trigger noise level value, then noise levels from new industrial-type noise sources, (including air-conditioning mechanical plant) need to be designed so that the cumulative effect does not produce total noise levels that would significantly exceed the project trigger noise level.

3.2.3 Area Classification

The NPfI characterises the "Suburban" noise environment as an area with an acoustical environment that:

- has local traffic with characteristically intermittent traffic flows or with some limited commerce or industry.
- This area often has the following characteristic: evening ambient noise levels defined by the natural environment and human activity

The area surrounding the proposed development falls under the "Suburban" area classification.

3.2.4 Project Specific Trigger Noise Levels

Having defined the area type, the processed results of the attended noise monitoring have been used to determine project specific project trigger noise level. The intrusive and amenity project trigger noise level for nearby residential premises are presented in Table 3-2. These project trigger noise levels are nominated for the purpose of assessing potential noise impacts from the proposed development.

For each assessment period, the lower (i.e. the more stringent) of the amenity or intrusive criteria are adopted. These are shown in bold text in Table 3-2.

	Time of	ANII 1 -	Mea	sured	Project specific	Noise Levels
Receiver	Day	LAeq(15min)	RBL ² L _{A90(15min)}	L _{Aeq} Noise Level)	Intrusive L _{Aeq(15min)}	Amenity ³ L _{Aeq(15min)}
	Day	55	37	51	42	55
Residential	Evening	45	37	50	42	45
	Night	40	32	45	37	40

Table 3-2 Project Specific Trigger Noise Levels (NPfl)

Note 1: ANL = "Acceptable Noise Level" for residences in Urban Areas.

Note 2: RBL = "Rating Background Level".

Note 3: Assuming existing noise levels are unlikely to decrease in the future

4 NOISE IMPACT ASSESSMENT

4.1 Road Traffic Noise

4.1.1 Road Traffic Noise Intrusion Assessment

In order to ascertain the existing noise levels from the surrounding area, the measured noise logger data was processed in accordance to the NSW Road Noise Policy assessment time periods. Table 4-1 details the traffic noise levels.

Table 4-1 Measured Traffic Noise Levels

	Noise Level – o	dB(A) re 20 μPa
Logger Location —	L _{Aeq (15hour)} 07:00 - 22:00	L _{Aeq (9hour)} 22:00 to 07:00
61 Fennell Street	57	50

Traffic noise levels recorded by the noise logger have been corrected to account for the distance from the road to the proposed façade. These are representative of the noise levels the proposed façade will encounter.

5 RECOMMENDED NOISE CONTROL TREATMENT

The calculation procedure establishes the required noise insulation performance of each surface component such that the internal noise level is achieved whilst an equal contribution of traffic noise energy is distributed across each component. Building envelope components with a greater surface area must therefore offer increased noise insulation performance.

The recommended acoustic treatments are based on the following floor finishes:

- Bedrooms: Hard Flooring and underlay
- Living Room Hard Flooring
- Kitchen/Wet Areas: Tiles

The acoustic requirements shown in this report will further increase where bedroom floor finishes are tiled or timbered.

All recommendations must be checked against others to ensure compliance with other non-acoustic requirements that Council or other authorities may impose (e.g. Thermal requirements for BASIX compliance).

5.1 Glazing

The R_w rating required for each window will vary from room to room. Recommendations for windows also apply to any other item of glazing located on the external facade of the building in a habitable room unless otherwise stated.

Note that the R_w rating is required for the complete glazing and frame assembly. The minimum glazing thicknesses will not necessarily meet the required R_w rating without an appropriate frame system. It will be therefore necessary to provide a window glass and frame system having a laboratory tested acoustic performance meeting the requirements acoustic requirements.

The window systems must be tested in accordance with both of the following:

- Australian Window Association Industry Code of Practice Window and Door Method of Acoustic Testing; and
- AS 1191 Acoustics Method for laboratory measurement of airborne sound insulation of building elements.

It is necessary to submit such Laboratory certification for the proposed glazing systems (i.e. windows and framing systems) (e.g. NAL or CSIRO) for approval by RSA Acoustics prior to ordering or commitment.

The entire frame associated with the glazing must be sealed into the structural opening using acoustic mastics and backer rods. Normal weather proofing details do not necessarily provide the full acoustic insulation potential of the window system. The manufacturers' installation instructions for the correct acoustic sealing of the frame must be followed.

It is possible that structural demands for wind loading or fire rating or the like may require more substantial glass and framing assemblies than nominated above. Where this is the case the acoustic requirements must clearly be superseded by the structural or fire rating demands.

5.1.1 Rw Requirements for Glazing

The glazing will be required to achieve a rating of $R_w 22$. This Rw rating is generally achieved with a standard aluminium frame, seals and 4mm monolithic glass panes. The glazing for the indoor communal room should be required to achieve a rating of $R_w 28$. This Rw rating is generally achieved with a standard aluminium frame, seals and 6mm monolithic glass panes. No further acoustic requirements are needed at present.

5.2 Mechanical Ventilation

The windows of the development can be opened for natural ventilation, where mechanical ventilation is desired, it must be approved by Council and in accordance with the relevant regulations such as the National Construction Code (NCC Vol.1, Part 4.5 *Ventilation of rooms*) and AS1668.2-2002 *The use of ventilation and air conditioning*.

6 OPERATIONAL NOISE ASSESSMENT

6.1 Mechanical Plant Noise Assessment

Finalised architectural layouts and specific mechanical plant selections have not been supplied at this stage. It is anticipated that the building will be serviced by typical mechanical ventilation/air conditioning and heating equipment.

It is likely that the criteria set out by Parramatta City Council and other regulatory standards will be met through the use of conventional noise control methods (e.g. selection of equipment on the basis of quiet operation and, where necessary, providing enclosures, localised barriers, silencers and lined ductwork).

An appropriately qualified acoustic consultant should review the mechanical plant associated with the development at the detailed design stage when final plant selections have been made and full mechanical plant assessment must then be carried out.

6.2 Typical Vocal Levels

Calculations of the amount of noise transmitted to these receivers from the proposed boarding house have been based on voice levels as referenced in the Handbook of Acoustical Measurements and Noise Control by Cyril M. Harris. This handbook provides voice spectrums for males and females as well as different vocal efforts. The spectrum is given in Table 6-1.

The spectra have been scaled based upon the overall number of patrons expected to be in the outdoor areas at any given time

Turno	No	oise Level	(dB) at Oct	tave Band	Centre Fre	equency (F	łz)	
туре	125	250	500	1 k	2 k	4 k	8 k	
Male (Raised)	49	55	58	51	47	43	37	58
Female (Raised)	37	51	54	49	44	43	38	55

Table 6-1 Speech Spectrums - Handbook of Acoustical Measurements and Noise Control.

6.3 Tenant Sound Power Levels

Based on a maximum assumed number of 12 tenants in the outdoor area (assuming that 23 people will live in the development, that being 22 tenants and 1 manager), the following worst-case operational scenarios have also been assumed for our assessment:

• An assumed total of 12 people in the outdoor area. Therefore, with 50 percent of the patrons talking, the worst-case scenario will be 6 tenants talking at any one time in the outdoor area.

Table 6-2 Sound Power Levels of People talking with Normal Voice - Lw - dB(A)

Connerio		Result	tant Soun	d Power Le	evel per C	ctave Bar	nd (dB)	
Scenario	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
6 Tenants with Normal Vocal in the Outdoor Area	-	67	73	76	69	65	61	55

6.4 Noise Emissions Calculation

Calculations of the noise levels from the operation of the proposed boarding house have been carried out using the data in tables 6-1 and 6-2. We have used the worst-case scenario where all noise is active at the same time. Calculations consider factors such as distance, shielding from buildings and barriers.

The following figure presents the proposed development and all sensitive receivers

Figure 6-1 Sensitive Receiver Location



6.5 Predicted Noise Levels

Predictive resultant noise levels have been calculated for residents using the communal area and car movements within the site. Noise emissions at the nearest residential receivers are presented in the table below. The predicted noise calculations consider the following:

- Heights of receivers are assumed to be 1.5 meters above ground level.
- A 1.6m balustrade on the northern façade of the outdoor communal area. (Please see Appendix E)
- A 1.8m solid boundary fence on the eastern southern and western facades.
- Up to 12 people will be in the outdoor communal area at a time (day and evening time only).
- The maximum capacity of the basement carpark is 10 we have assumed an operational scenario where 5 cars leave the parking area at the same time.

Receiver	Period	Calculated Noise Level L _{Aeq} – dB(A)	Criteria	Compliance
	Day	35	42	Yes
R1	Evening	35	42	Yes
	Night	35	37	Yes
	Day	34	42	Yes
R2	Evening	34	42	Yes
	Night	34	37	Yes
	Day	<30	42	Yes
R3	Evening	<30	42	Yes
	Night	<30	37	Yes
	Day	42	42	Yes
R4	Evening	42	42	Yes
	Night	42	37	No

 Table 6-3
 Predicted Noise Levels at sensitive receivers.

It is likely that most tenants will use the common room, however, all tenants must be instructed to minimise noise while using the outdoor areas to minimise unnecessary intrusion. We note that our calculations assumed that the outdoor common areas will only be used by the tenants.

6.6 Outdoor Communal Area Mitigation Recommendations

To ensure the future amenity of nearby sensitive receivers most notably the residential development to the west, the following recommendations should be put in place:

- A 1.6m balustrade on the western façade of the outdoor communal area. (Please see Appendix E).
- No music is to be played in the outdoor communal area.
- No tenants are allowed to use the outdoor area from 10pm 7am.

++++



7 CONCLUSION

Rodney Stevens Acoustics has conducted a noise impact assessment of the proposed boarding house development located at 61 Fennell Street, North Parramatta. The review has assessed the noise intrusion of the site and compared it with the noise criteria required by in Parramatta City Council and other relevant standards including the EPA's Noise Policy for Industry.

A noise survey has been carried out and the processed data has been used to determine traffic noise from the surrounding area to the project site. Based on the noise impact study conducted, the proposed development is deemed to comply with the SEPP (Infrastructure) 2007-noise criteria with recommendations from this report. It is therefore recommended that planning approval be granted for the proposed development based on acoustics.

Approved: -

un O. Stermo

Rodney Stevens Manager/Principal

Appendix A.	Acoustic Terminology
A-weighted sound pressure	The human ear is not equally sensitive to sound at different frequencies. People are more sensitive to sound in the range of 1 to 4 kHz (1000 – 4000 vibrations per second) and less sensitive to lower and higher frequency sound. During noise measurement, an electronic ' <i>A-weighting</i> ' frequency filter is applied to the measured sound level $dB(A)$ to account for these sensitivities. Other frequency weightings (B, C and D) are less commonly used. Sound measured without a filter is denoted as linear weighted dB(linear).
Ambient noise	The total noise in a given situation, inclusive of all noise source contributions in the near and far field.
Community	Includes noise annoyance due to:
annoyance	 character of the noise (e.g. sound pressure level, tonality, impulsiveness, low-frequency content)
	 character of the environment (e.g. very quiet suburban, suburban, urban, near industry)
	 miscellaneous circumstances (e.g. noise avoidance possibilities, cognitive noise, unpleasant associations)
	 human activity being interrupted (e.g. sleep, communicating, reading, working, listening to radio/TV, recreation).
Compliance	The process of checking that source noise levels meet with the noise limits in a statutory context.
Cumulative noise level	The total level of noise from all sources.
Extraneous noise	Noise resulting from activities that are not typical to the area. Atypical activities may include construction, and traffic generated by holiday periods and by special events such as concerts or sporting events. Normal daily traffic is not considered to be extraneous.
Feasible and reasonable measures	Feasibility relates to engineering considerations and what is practical to build; reasonableness relates to the application of judgement in arriving at a decision, taking into account the following factors:
	 Noise mitigation benefits (amount of noise reduction provided, number of people protected).
	 Cost of mitigation (cost of mitigation versus benefit provided).
	 Community views (aesthetic impacts and community wishes).
	 Noise levels for affected land uses (existing and future levels, and changes in noise levels).
Impulsiveness	Impulsive noise is noise with a high peak of short duration or a sequence of these peaks. Impulsive noise is also considered annoying.

)))

Low frequency	Noise containing major components in the low-frequency range (20 to 250 Hz) of the frequency spectrum.
Noise criteria	The general set of non-mandatory noise levels for protecting against intrusive noise (for example, background noise plus 5 dB) and loss of amenity (e.g. noise levels for various land use).
Noise level (goal)	A noise level that should be adopted for planning purposes as the highest acceptable noise level for the specific area, land use and time of day.
Noise limits	Enforceable noise levels that appear in conditions on consents and licences. The noise limits are based on achievable noise levels, which the proponent has predicted can be met during the environmental assessment. Exceedance of the noise limits can result in the requirement for either the development of noise management plans or legal action.
Performance- based goals	Goals specified in terms of the outcomes/performance to be achieved, but not in terms of the means of achieving them.
Rating	
Background Level (RBL)	representing background level is the overall single figure background level representing each day, evening and night time period. The rating background level is the 10 th percentile min L _{A90} noise level measured over all day, evening and night time monitoring periods.
Background Level (RBL) Receptor	The rating background level is the overall single figure background level representing each day, evening and night time period. The rating background level is the 10 th percentile min L _{A90} noise level measured over all day, evening and night time monitoring periods. The noise-sensitive land use at which noise from a development can be heard.
Background Level (RBL) Receptor Sleep disturbance	The rating background level is the overall single figure background level representing each day, evening and night time period. The rating background level is the 10 th percentile min L _{A90} noise level measured over all day, evening and night time monitoring periods. The noise-sensitive land use at which noise from a development can be heard. Awakenings and disturbance of sleep stages.
Background Level (RBL) Receptor Sleep disturbance Sound and decibels (dB)	The rating background level is the overall single figure background level representing each day, evening and night time period. The rating background level is the 10 th percentile min L _{A90} noise level measured over all day, evening and night time monitoring periods. The noise-sensitive land use at which noise from a development can be heard. Awakenings and disturbance of sleep stages. Sound (or noise) is caused by minute changes in atmospheric pressure that are detected by the human ear. The ratio between the quietest noise audible and that which should cause permanent hearing damage is a million times the change in sound pressure. To simplify this range the sound pressures are logarithmically converted to decibels from a reference level of 2 x 10-5 Pa.

((((((() ©



dB is the abbreviation for decibel – a unit of sound measurement. It is equivalent to 10 times the logarithm (to base 10) of the ratio of a given sound pressure to a reference pressure.

Sound power Level
(SWL)The sound power level of a noise source is the sound energy emitted by
the source. Notated as SWL, sound power levels are typically presented
in dB(A).

SoundPressureThe level of noise, usually expressed as SPL in dB(A), as measured by aLevel (SPL)standard sound level meter with a pressure microphone. The sound
pressure level in dB(A) gives a close indication of the subjective loudness
of the noise.

Statistic noise Noise levels varying over time (e.g. community noise, traffic noise, construction noise) are described in terms of the statistical exceedance level.

A hypothetical example of A weighted noise levels over a 15-minute measurement period is indicated in the following figure:



Key descriptors:

- L_{Amax} Maximum recorded noise level.
- L_{A1} The noise level exceeded for 1% of the 15 minute interval.



L_{A10} Noise level present for 10% of the 15-minute interval. Commonly referred to the average maximum noise level.

L_{Aeq} Equivalent continuous (energy average) A-weighted sound pressure level. It is defined as the steady sound level that contains the same amount of acoustic energy as the corresponding time-varying sound.

 L_{A90} Noise level exceeded for 90% of time (background level). The average minimum background sound level (in the absence of the source under consideration).

Threshold The lowest sound pressure level that produces a detectable response (in an instrument/person).

Tonality Tonal noise contains one or more prominent tones (and characterised by a distinct frequency components) and is considered more annoying. A 2 to 5 dB(A) penalty is typically applied to noise sources with tonal characteristics





((((((())))



61 Fennell St

Ambient

Sunday 27/5/18



((((((() ©

Ambient 28/5/18 Monday 90 85 80 75 45 40 35 30 21:00 00:0 1:00 2:00 3:00 4:00 7:00 13:00 17:00 18:00 20:00 22:00 23:00 0:00 5:00 6:00 8:00 9:00 0:00 11:00 14:00 15:00 16:00 19:00 12:00 Time 24hrs → L1 → L10 → L90 → Leq

61 Fennell St

Ambient





||||||| (C





(((((((



Time 24hrs ← L1 --- L10 --- L90 --- Leq



61 Fennell St

Traffic



61 Fennell St Traffic 28/5/18 Monday 90 85 80 75 Sound Pressure Level dB(A) 70 65 60 55 50 45 40 35 30 14:00 17:00 21:00 23:00 00:0 1:00 3:00 4:00 6:00 7:00 8:00 13:00 15:00 18:00 20:00 22:00 2:00 5:00 9:00 0:00 11:00 12:00 16:00 19:00 0:00 Time 24hrs → L1 → L10 → L90 → Leq 61 Fennell St Traffic Tuesday 29/5/18 90 85 80 75 Sound Pressure Level dB(A) 70 65 60 55 50 45 40 35 30

12:00 13:00 14:00 15:00 16:00 17:00

Time 24hrs

10:00 11:00

9:00

0:00 1:00 3:00 5:00 6:00 7:00 8:00 22:00 23:00

0:00

18:00

19:00 20:00 21:00 



||||||||[







01 FIRST FLOOR PLAN SCALE 1:100042

				DA APPLICATION
ArchNecture Interior Design Project Management	The second secon	BAT BEY ECCOPTION 101: 2017 - Prel-CA 10: COMAC. - 2017: 103 - Prel-CA 10: COMAC. - WF 2019 - A 10: COMAC. - WF 2019 - A 10: COMAC. -	06488.87 045000 87 28 88 20/04 88 25/04 88	IT. FIRST FLOOR MANTER PLAN BO FIT LET B LET HIL CAMBONIX M J CARBONN LET HIL CAMBONIX M J CARBONN B 6 55



01 SECOND FLOOR PLAN SCALE 1:100842

DA APPLICATION

(((((((

2		_							
bossdəsign	NEW HEAV	DATE 000 2017 5077 201	REV	DESORPTION DR PRE-DA TO COLINGL DA TO COLINGL Z	RAIN BY 25. 25./08.44A	NE DEDED	\oplus	PROJECT 61 FERREL ST. NORTH PARRAMENTA NOW, 2151	SECOND FLOOR PLAN
Architecture Interior Design Project Management		WAY 2025		REHED OF 10 COUNCIL 2	2к,на	<u>к</u>		CLENT WARINGA NO 1 PTY LTD GLETKHAN NOMIKEES PTY LTD F GADNONI, E M A GAGNONI & M J GAGNONI PROJECT NO 2017-125	RL 17.33 8_06



6)) Research	Pennai Ph: +61	1 Hills NSW AL 2 9484 0800 A.B.I	JSTRALIA 212 N. 65 160 399 11	o 9	
V	Labs Pty Ltd	www	.acousticresea	rch.com.au		
	Sound	Leve	I Meter			
	Calibrati	on (ertificate			
	Calibration Number	C17	323			
	Client Details	Rodne	ey Stevens Acoustics	Pty Ltd		
		1 Maj St Ive	ura Close s Chase NSW 2075			
Equipr	nent Tested/ Model Number :	Rion	NL-42EX			
	Instrument Serial Number : Microphone Serial Number :	00572 17037	542 '0			
I	Pre-amplifier Serial Number :	72880				
Pre-Test At Ambient Ten	mospheric Conditions aperature : 23.4°C		Post-Test Atm Ambient	Temperature :	23.3°C	
Relative Barometric	Humidity : 37.2% Pressure : 99.65kPa		Relat	tive Humidity : etric Pressure :	37.8% 99.52kPa	
Calibration Techn	ician : Lucky Jaiswal	Na A	Secondary Check	: Riley Cooper		
Calibration	Date : 03/07/2017		Report Issue Date	: 04/07/2017	Juan Aguero	
Clause and Charact	Approved Signatory :	sut	Clause and Charac	teristic Tested	Result	
12: Acoustical Sig. test	s of a frequency weighting P	ass	17: Level linearity incl	the level range con	ntrol Pass	
13: Electrical Sig. tests 14: Frequency and time	e weightings at 1 kHz Pa	ass ass	18: Toneburst response 19: C Weighted Peak S	ound Level	Pass Pass	
15: Long Term Stabilit	y Po he reference level range Po	ass ass	20: Overload Indication 21: High Level Stabilit	n V	Pass Pass	
To: Dever finearity on t						
The sound level meter su	bmitted for testing has successfully comp conditions under wh	pleted the hich the te	class 2 periodic tests of Il ests were performed.	EC 61672-3:2006, for	the environmental	
However, no general state 1:2002 because evic demonstrate that the mod	ement or conclusion can be made about c lence was not publicly available, from ar del of sound level meter fully conformed IEC 61672-3:2006 cover only a limited	onformar independ to the rec subset of	tee of the sound level meter lent testing organisation re purements in IEC 61672- the specifications in IEC 6	er to the full requirem esponsible for pattern 1:2002 and because th 61672-1:2002.	ents of IEC 61672- approvals, to ne periodic tests of	
Acoustic Tests	Least Uncerta	inties of M	Measurement -		all the second second	
31.5 Hz to 8kHz 12 5kH=	$\pm 0.16dB$ $\pm 0.2dB$	Te	emperature elative Humidity	$\pm 0.05^{\circ}C$ $\pm 0.46\%$		
16kHz Electrical Tests	$\pm 0.29 dB$	Be	arometric Pressure	±0.017kPa		
31.5 Hz to 20 kHz	±0.12dB					
- Annal Salta	All uncertainties are derived at the 95	5% confid	ence level with a coverage	e factor of 2.		
And the second	This calibration certificate is to be rea	nd in conj	unction with the calibratio	n test report.		
NATA	Acoustic Research Labs Pty Ltd is NA Accredited for compliance with ISO/	ATA Acc IEC 1702	redited Laboratory Numbe 5.	er 14172.		
NAIA	The results of the tests, calibrations at Australian/national standards.	nd/or mea	surements included in this	document are tracea	ble to	
WORLD RECOGNISED	NATA is a signatory to the ILAC Mu	itual Reco	gnition Arrangement for t	he mutual recognitior	n of the	
	equivalence of testing, medical testing	g, calibrat	ion and inspection reports	· And the stand		

((((((()©

Appendix E Communal Area Balustrade

In addition to the timber louvered privacy screen, a 1.6m high solid balustrade must be implemented on the western boundary of the communal terrace and is required to provide adequate noise attenuation, the construction material of the barrier must have a surface density of 10-15 kg/m' and be free from holes and gaps. Some suitable materials include:

- 12 mm thick Perspex, polycarbonate or Danpalon
- 6 mm toughened laminated safety glass
- Any other approved material which meets the above surface density specification

A typical material used in childcare centres is Perspex, which is a polycarbonate material. The use of the 12 mm thick Perspex or 6 mm glass for this purpose which has a surface mass of 11 kg/m' will meet the mass requirements detailed above and be suitable for use as it is transparent and will not unduly restrict light or vision.

All barriers must be free of gaps and penetrations and it is particularly important to ensure that the gap at the bottom of the barrier is minimised as far as practicable. The base of the barriers should be well sealed at the junction where the barrier meets the floor, but still be designed to allow proper water drainage. See below for barrier layout:

