
OFFICIAL

Andrew

I submitted the following on Portal (not the Major Projects part):

According to the Response to Submissions Report Central Barangaroo Concept Plan MP06_0162 Modification 9 of November 2023 and the Preliminary Aeronautical Impact Assessment Addendum – Concept Plan MP06_0162 MOD 9 of 17 August by Avlaw, the revised maximum building height will be reduced from 73.7m to 42.5m. The crane heights will be reduced and will be below the Obstacle Limitation Surfaces for Sydney Airport. Therefore, controlled activity approval will not be required for the buildings or cranes.

CASA maintains no objections to the proposal. CASA agrees with Section 9.9.4 Aviation of the Response to Submissions Report that ‘no further assessment is deemed necessary’.

Regards

David Alder
Aerodrome Engineer
Air Navigation, Airspace and Aerodromes Branch
ph : 02 62171342 **m**: 0455051611
18 Marcus Clarke Street, Canberra, ACT, 2605
www.casa.gov.au