



NSW RURAL FIRE SERVICE



Planning,
Industry &
Environment

Issued under the Environmental Planning and Assessment Act 1979

Approved Application No DA 10659

Granted on the 18 October 2021

Signed M Brown

Sheet No 21 of 21

Dept. Of Planning - Alpine
PO Box 36
Jindabyne NSW 2627

Your reference: (CNR-16368) DA 10659
Our reference: DA20210115000152-Original-1

ATTENTION: Mark Brown

Date: Wednesday 12 May 2021

Dear Sir/Madam,

Integrated Development Application
s100B – SFPP – Other Tourist Accommodation
2 BRINDLE BULL CL THREDBO NSW 2625, 746//DP1119757

I refer to your correspondence dated 12/01/2021 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

The intent of measures is to provide sufficient space for fire fighters and other emergency services personnel, ensuring radiant heat levels permit operations under critical conditions of radiant heat, smoke and embers, while supporting or evacuating occupants. To achieve this, the following conditions shall apply:

1. At the commencement of building works, and for the life of the development, all land within the subject leasehold site must be managed as an inner protection area (IPA) in accordance with Appendix 4 of *Planning for Bush Fire Protection 2019*.

Construction Standards

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

2. New construction must comply with section 3 and section 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bushfire-prone areas* or the relevant BAL 12.5 requirements of the NASH Standard - *Steel Framed Construction in Bushfire Areas (incorporating amendment A - 2015)*. New construction must also comply with the construction requirements in Section 7.5 of *Planning for Bush Fire Protection 2019*.

3. The existing building is required to be upgraded to improve ember protection (if not already constructed to the relevant Bushfire Attack Level under Australian Standard AS3959). Ember protection can be achieved by

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

enclosing all openings (excluding roof tile spaces) or covering openings with a non-corrosive metal screen mesh with a maximum aperture of 2mm. Where applicable, this includes any subfloor areas, openable windows, vents, weep holes and eaves. External doors are to be fitted with draft excluders.

Water and Utility Services

The intent of measures is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building. To achieve this, the following conditions shall apply:

4. The provision of all new and the modification of any existing water, electricity, and gas services must comply with Table 6.8c of *Planning for Bush Fire Protection 2019*.

Landscaping Assessment

The intent of measures is for landscaping. To achieve this, the following conditions shall apply:

5. All landscaping within the site must comply with Table 6.8a of *Planning for Bush Fire Protection 2019*.

Emergency and Evacuation Planning Assessment

The intent of measures is to provide suitable emergency and evacuation (and relocation) arrangements for occupants of special fire protection purpose developments. To achieve this, the following conditions shall apply:

6. A Bush Fire Emergency Management and Evacuation Plan must be prepared consistent with the NSW RFS document *A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan*. The Plan should include planning for the early relocation of occupants. Detailed plans of all Emergency Assembly Areas including “on-site” and “off-site” arrangements as stated in Australian Standard 3745:2010 *Planning for Emergencies in Facilities* must be displayed, and an annual (as a minimum) trial emergency evacuation is conducted.

For any queries regarding this correspondence, please contact Bradley Bourke on 1300 NSW RFS.

Yours sincerely,

Anna Jones

**Supervisor Development Assessment & Plan
Built & Natural Environment**



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

SFPP – Other Tourist Accommodation
2 BRINDLE BULL CL THREDBO NSW 2625, 746//DP1119757
RFS Reference: DA20210115000152-Original-1
Your Reference: (CNR-16368) DA 10659

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Anna Jones

**Supervisor Development Assessment & Plan
Built & Natural Environment**

Wednesday 12 May 2021